



**Washington State
Department of Transportation**

State Materials Laboratory
1655 S 2nd Ave SW
Tumwater, WA 98512-6951
360-709-6400 / FAX: 360-709-6586
TTY: 1-800-833-6388
www.wsdot.wa.gov

January 9, 2019

Patrick Mulhall
Polylok, Inc.
3 Fairfield Blvd.
Wallingford, CT 06762
(877) 765-9565

Re: QPL Product Evaluation, QPL2018108

Mr. Mulhall,

The evaluation of Polylok Slab Bolsters, reinforcing steel support devices, manufactured in Wallingford, Connecticut, has been completed.

The product review indicates that this product meets the requirements of Section 6-02.3(24)C of the 2018 WSDOT Standard Specifications for Road, Bridge, and Municipal Construction (August Amendment) and has been added to the Qualified Products List (QPL). A copy of the listing, as found in the QPL, is enclosed.

The acceptance code for this product will be "3101". Acceptance code "3101" states: Visually verify the product delivered to the job site is the product that was originally submitted by the Contractor and approved from the QPL. Note 'Restrictions' when present.

The QPL may be found on the Internet at:

http://www.wsdot.wa.gov/biz/mats/QPL/QPL_Search.cfm

If there are any questions concerning this matter, please contact Maha Ablson at (360) 709-5442.

Sincerely,

Pat Norton
Assistant Materials Quality Assurance Engineer

PN:rzk
Enclosure



[Traffic & Cameras](#) | [Projects](#) | [Business](#) | [Environment](#) | [Maps & Data](#)

[Email updates](#)

You are here: [Home](#) > [Business](#) > [Materials Laboratory](#)

Qualified Product List

Product Information

Manufacturer : [Polylok, Inc., Wallingford - CT](#)

Product Name : Polylok Slab Bolsters

Standard Spec : 6-02.3(24)C, Reinforcing Steel - Support Devices - Plastic

Product Description : All-plastic support bolster for reinforcing steel, 3/4" to 3"

Product Restriction :

The product shall not be used in a stacked configuration if it prevents complete concrete consolidation in and around the support.

Acceptance Code : 3101

Code Description : Visually verify the product delivered to the job site is the product that was originally submitted by the Contractor and approved from the QPL. Note 'Restrictions' when present.

Last Updated : Jan 8, 2019

Contractors with WSDOT [Click here for Contractor Product Info Page](#)