

POLYLOK TEST FACILITY  
3 Fairfield Blvd  
Wallingford, CT 06492

Report Date..... 9-Oct-09  
EML Project ID..... 091002-POL  
Your Project ID..... PL 625  
Your Project P O #..... 1919  
Date Sampled..... 2-Oct-09  
Date Submitted..... 2-Oct-09

Attn: Mr. Peter Gavin

Values in mg/L unless otherwise noted.  
ND = Not Detected. NR = Not Required.


Parameter	#625 Before
-----------	----------------

Biochemical Oxygen Demand 4933.


Total Suspended Solids 7700.

Tab:Blankp1


Technical Reviewer:



Title:



Transcript Reviewer:



Title:



ENVIRONMENTAL MONITORING LABORATORY, INC.

POLYLOK TEST FACILITY  
3 Fairfield Blvd  
Wallingford, CT 06492

Report Date..... 9-Oct-09  
EML Project ID..... 091002-POL  
Your Project ID..... PL 625  
Your Project P O #..... 1919  
Date Sampled..... 2-Oct-09  
Date Submitted..... 2-Oct-09

Attn: Mr. Peter Gavin

Values in mg/L unless otherwise noted.  
ND = Not Detected. NR = Not Required.

Parameter	#625 After
-----------	---------------

Biochemical Oxygen Demand 143.8

Total Suspended Solids 46.

Tab:Blankp1

Technical Reviewer: [Signature]

Title: [Signature]

Transcript Reviewer: [Signature]

Title: [Signature]



ENVIRONMENTAL MONITORING LABORATORY, INC.